

Voltage Regulation and Protection Assurance using DER Advanced Grid Functions

Jay Johnson
jjohns2@sandia.gov
Sandia National Laboratories
ENERGISE
32931


SYSTEMS INTEGRATION

PROJECT OVERVIEW

This project is creating open-source components for a commercial platform to address the spectrum of distribution circuit and DER management, including: state estimation, voltage regulation, protection, economic optimization, communications and cybersecurity. This solution will safely allow PV penetrations of 50% or greater by providing real-time visibility into distribution circuits and optimizing the active and reactive power (P/Q) DER settings to meet voltage regulation, protection and economic objectives in the presence of forecast uncertainty.

PROJECT OBJECTIVES


- Provide real-time feeder visibility/visualization
- Operate DERs to keep feeder voltages within ANSI C84.1-2006 limits
- Maintain protection with high penetrations of DER on distribution circuits
- Minimize economic costs using multi-objective optimization
- Create information exchange recommendations
- Generate cyber security recommended practices




TECHNOLOGY OVERVIEW

Georgia Tech and Sandia technologies will be released as open-source code or algorithms and incorporated into a commercial software product developed by BPL Global. The core technologies being developed are:


1. Distribution System Distributed Quasi-Dynamic State Estimator
 - Generates the voltage profile and power flow estimation with scalable solution from feeder telemetry
 - Operates on partitioned distribution system with solutions at up to 60 times/second



2. Estimation-Based Protection
 - Detects faults and protects the system by isolating the faulted section of circuit
 - Signals reclosers, breakers, or other switching operations
 - Operates extremely fast after collecting state-estimation results (typically below 1 ms)



3. Persistence forecasting
 - Uses historical data and clear sky index to generate PV power forecast
 - 1-15-sec time-step with a 10-min horizon
 - Forecast uncertainty characterized by historical record to be used in the optimization



4. Robust optimization taking into account forecast uncertainty
 - Construct an uncertainty set Ω for the DER power injections
 - Define DER power injections in terms of u^t

$$\Omega^t(R^t, \delta^t, \sigma^t) = \left\{ u^t \in \mathbb{R}^N : \sum_{i \in I} \frac{|u_i^t - \bar{u}_i^t|}{\sigma_i^t} \leq \delta^t, u_i^t \in [\bar{u}_i^t - \sigma_i^t, \bar{u}_i^t + \sigma_i^t] \forall i \in I \right\}, \Omega = \prod_{t=1}^T \Omega^t$$


where I is the set of all DERs with uncertain injections for time intervals in T
 u^t : vector of uncertain DER power injections
 \bar{u}_i^t : nominal value of the DER power injection
 $[\bar{u}_i^t - \sigma_i^t, \bar{u}_i^t + \sigma_i^t]$: range of uncertainty
 δ^t : Budget of uncertainty set

See: D. Bertsimas, E. Litvinov, A. Sun, J. Zhao, and T. Zheng, Adaptive Robust Optimization for the Security-Constrained Unit Commitment Problem, IEEE Transactions on Power Systems, 28, 1, 52-63, 2013.

DER CYBER SECURITY

- The SunSpec/Sandia DER Cyber Security Working Group was initiated as part of this project and has already gathered hundreds of stakeholders to discuss DER cyber security.
- The workgroup covers security for DER devices, gateways, and other networking equipment, owned or operated by end users, aggregators, utilities, and grid operators.
- **Primary Goal: Generate a collection of best practices that act as basis for a national or international DER cyber security standard.**
- Secondary Goal: facilitate DER cyber security discussions between stakeholders to exchange perspectives and (hopefully) gain broad buy-in from the industry for the recommendations.

<https://sunspec.org/sunspec-cybersecurity-workgroup/>




DER Cyber Security Working Group working groups and activities.

SYSTEM ARCHITECTURE AND OPERATIONS

Programmable Distribution Resource Open Management Optimization System (ProDROMOS)

(ProDromos is Greek for "forerunner" and the prodromoi were a light cavalry army unit in ancient Greece used for scouting missions.)



1. Distribution System Distributed Quasi-Dynamic **State Estimator** (DS-DQSE) ingests feeder telemetry, DER and customer data, and generates the voltage profile and power flow estimation.
2. The **Estimation-Based Protection** (EBP) scheme detects faults and protects the system by isolating the faulted section of the distribution circuit by recloser/breaker/switching operations.
3. The **forecasting** component provides short-term (e.g., 10 minute) forecasts of PV power output and load using recent system states and statistical irradiance modeling in conjunction with PV performance models.
4. A **dispatch optimization engine** determines the necessary active and reactive (P/Q) power settings for groups of DERs to maintain voltage and distribution protection systems for the next time period (~1-5 minutes) considering the economic impact of curtailment and non-unity power factor operations.
5. The **communications system** uses the SCADA and DER control network to update DER operations and get new data from the power system.

DEMONSTRATION WITH POWER HARDWARE-IN-THE-LOOP

The ProDROMOS system will be demonstrated using a power hardware-in-the-loop system (PHIL) at the Distributed Energy Technologies Laboratory (DETL) at Sandia and in a field demonstration on a National Grid feeder with a utility-scale PV installation.

