

Safeguards and Security for Maritime Applications

PRESENTED BY

Anna Taconi and Kevin Norbash May 2024





Background



- Floating Nuclear Power Plants (FNPPs) are being considered for a variety of applications
 - Stationary offshore plants for remote applications
 - Mobile plants able to provide power as emergency relief for natural disasters
 - Clean energy propulsion for cargo ships
 - Floating charging stations for battery powered vessels
- FNPPs will need unique physical protection systems (PPS) to meet their unique needs

Challenges to Security Design for FNPPs



- Water based attacks vessel or submerged
 - Detection methods
 - Physical protection design
- Balance between effective and practical protection
 - Ex: When considering a homemade sub-aquatic missile: is an underwater fence or net enough, or will there need to be a submerged concrete fence or a man-made cove surrounding the FNPP?

Preliminary PPS Design



Assumptions:

- Strict reliance on off-site response
- Adversary has knowledge of FNPP layout
- Adversary taking most vulnerable path from dock to target

Current delay methods:

- Barriers fence surrounding ship, steel doors, lead walls
- Cameras located in entry points, stairwells, and along the main deck
- Patrol along the main deck

First Iteration of PPS Design



Initial Design:

- Chain link fence around the main deck
- Steel walls of varying thickness around the different units and rooms
- Steel doors
- Shatter-proof windows on main deck for operators' quality of life
- Reinforced concrete around cooling pond and reactor

Results of Initial Design:

- Probability of detection for all 3 scenarios was 1.
- Offsite response was too slow with the given delays in the system

Current Iteration of PPS Design



Changes Made

- Removed all windows
- Upgraded all doors to 10 cm wood with metal sheeting
- Upgraded doors to vital areas to 30 cm wood with metal sheeting or steel and concrete rolling doors
- Increased thickness vital area walls

Results for current design

- Probability of detection for all scenarios is 1
- Added delays significantly aided response force

Conclusions so far:

- Response forces arrive before completion of adversary task with a minimum standard of 0.95 for the probability of interruption for the given design and attack paths
- A response force located on board significantly increases the probability of interruption
- More iterations can significantly improve the design

Future Work



- Refine PPS design to find balance between effective and practical protection
 - Offsite vs Onsite Response
 - Economic Analysis
 - Force on Force simulation
- Expand analysis to include water-based attacks
 - PathTrace and Scribe3D will require development to simulate water-based attacks on the plant
 - Work with sensor development to discuss best monitoring options to detect submerged and vessel adversaries

References



- A. Larionov, European Nuclear Society webinar: "Rosatom SMR solutions: floating nuclear power plants and beyond", https://www.youtube.com/watch?v=RT8q9McmhBM, May 7, 2020.
- 2. A. Orr, P. Zahnle, "PathTrace and MPVEASI: A Path Analysis Comparative Validation Study", September 2023.
- 3. International Training Course on the Physical Protection of Nuclear Material and Nuclear Facilities Document, The 29th International Training Course (ITC).