



Energy Storage Safety Codes, Standards, & Regulations (CSRs)



Waylon Clark/Sandia Energy Storage Demonstration Projects Team Lead

Presented to the California Energy Commission – Webinar Series


November 1st, 2024





Sandia National Laboratories is a multimission laboratory managed and operated by National Technology & Engineering Solutions of Sandia, LLC, a wholly owned subsidiary of Honeywell International Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA0003525.

SAND2024-14957PE



Sandia Energy Storage Program Thrust Area

D E M O N S T R

Sandia's Demonstration Projects

We facilitate the early adoption of energy storage technologies in support of the U.S. Department of Energy's (DOE) goals of an equitable, clean, resilient, and secure grid of the future

TAct as a bridgeValidateRbetween R&D andmodelsAcommercializationcollege


Validate technical models through collection of

data

Inform Codes,
Standards, &Increase public
confidence byRegulations (CSRs)demonstrating ESdevelopment andand showcasing

installation best practices its range of benefits

Demonstration Projects Are a Foundational Element of the DOE/SNL Energy Storage Program



Current Sandia ES Demonstration Projects



U.S. Energy Storage Installation Codes, Standards, & Regulations (CSRs)





Image courtesy of PNNL



Product Listing - Safety Standard/Code Relationship



Standard

Installation Standards/Codes

National Fire Protection Association (NFPA) 855

2020 NFPA 855 Standard for the Installation of Stationary ESS

- 1st Edition published (8/25/19)
- Scope reserved for next cycle based on appeal by utilities for exemptions
- Covers
 - Installation
 - Explosion Control
 - Commissioning
 - O & M
 - Emergency Response
 - Decommissioning

2023 NFPA 855 was approved as of 9/1/2022




National Fire Protection Association (NFPA) 855

2023 NFPA 855 Standard for the Installation of Stationary ESS – *Significant Changes*

- Utilities are not exempt from this standard although there are carve outs (exemptions) within certain sections
- Updated requirements for storage of Lithium Metal or Lithium-ion batteries
- System augmentation

2026 NFPA 855 Standard for the Installation of Stationary ESS – *In Second Draft Stage*

- Example of some of the Task Groups and content are:
 - Roof top PV and ESS, Charging Stations, ESS on Barges, 2 Life Use, ...








Lessons Learned & Examples

10

Many Manufacturers & Integrators don't understand NFPA 855 Requirements


• Especially true as related to explosion mitigation



Option: Deflagration Venting (Blow out panels)



Option: Venting Solutions



International Fire Code

2021 International Fire Code

- Section 1206
- Changes from 2018
- Scope ads O&M, retrofit, commissioning, decommissioning
- Exemption for telecom using Pb & NiCd @<60 VDC
- Suppression system based on 9540a
- Dedicated / Non-dedicated use buildings
- Explosion control: NFPA68 or 69

2024 International Fire Code

- Section 1207 Electrical Energy Storage Systems (ESS)
 - Continued language alignment with NFPA 855 Scope section of 1207 reads, "Material based on NFPA 855 2023 Ed."
- Future editions are expected to simply point to NFPA855 as the default standard for installation of energy storage systems




UL9540ATest Methodology

Evaluating/interpreting test results can be challenging



Credit: FM Global







Purpose:

Determine if thermal runaway can be induced,

If so, document thermal runaway methodology, instrumentation,

Determine cell surface temp at venting and thermal runaway,

Measure gas generation and composition.












Image Credit: UL

Purpose:

Evaluate thermal runaway propagation within a module,

Develop data on heat release rate and vent gas generation rate and composition,

Document fire and deflagration hazards.










Image Credit: UL

UL 9540 A Unit Level Testing

Document thermal runaway progression within the unit,

Document if flaming occurs outside the unit,

Measure heat and gas generation rates,

Measure surface temperatures and heat fluxes in target units,

Measure surface temperatures and heat fluxes on walls.




Image Credit: UL



Acceptable results:

No flaming outside the unit under test *

No explosion hazard observed (incl gases <25% LEL)

Maximum temperatures on target units \leq the vent temperature in the cell level test, and maximum surface wall temperature rise \leq 97 °C (175 °F) above ambient.

* If flaming is observed, the test will be conducted with a manufacturer recommended automatic sprinkler system or other fire protection system present.






Three Primary ES Safety Focus Areas Identified

17

This is from a multi-lab proposal Sandia made to the DOE called, *"Multi-technology Energy Storage Safety (MTESS) At The System Level".*

These safety solutions would predominately fall under the "Engineered Solutions" option within NFPA 855



18 Application of an "Engineered Solution"



PNNL Intellivent – Automatic Door Opening System Doors open in response to a signal from one or a combination of gas detection, smoke/heat detectors Deployed at PNNL Lab Site ٠ Field deployed on a joint Sandia/PNNL project Requires a UL9540A installation level test to become an accepted 'engineered solution'

> Field Demonstration Project Site Intellivent Installation

ESS deployments funded by CEC programs (either wholly or partially) should be required to comply with the most current Fire and Safety Codes/Standards* **(specifically NFPA 855)

Request for Proposals (RFP's) should include language specifying adherence to the most current Fire and Safety Codes/Standards regardless of the Code of Record at the deployment location*

Evaluate bid proposals and vendors closely to ensure they understand what is required and their proposed system design reflects the requirements and meets the intent of specified CSRs

*Exceptions should be made for first-gen or pilot projects where it is understood and known that the system may fail (within reason)

**My personal opinion

Thank You For Your Attention Questions?

Additional questions/comments, contact: <u>wtclark@sandia.gov</u>

This material is based upon work supported by the U.S. Department of Energy, Office of Electricity (OE), Energy Storage Division.

